

KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

Fuji Tusco Co., Ltd.

Samutprakarn, Thailand

has successfully passed the type test sequence on a
three-phase oil-immersed

distribution transformer

Type: 225-24M

Rating: 24 kV - 4 x 2,5% / 0,416 kV - 225 kVA - Dyn1 - 50 Hz

The test object passed the specification of test duties of

IEC 60076

The test results are recorded in Certificate No.

2412-15

This Certificate is issued on 23 March 2016

KEMA Nederland B.V.



J.P. Fonteijne
Executive Vice President
KEMA Laboratories

KEMA

Laboratories

